

**REQUEST FOR VARIANCE(S) FROM BOARD OF HEALTH**  
**DECISION NEEDED BY SEPTEMBER 30, 2022**

STREET ADDRESS: 25 Kingstown Way

CURRENT BEDROOMS: 4 DSCP REQUESTED BEDROOMS: 4

PARCEL #: 048-036-004

CURRENT OWNER: Folajide Properties LLC

MOVE: To **Grant/Deny** a variance to Duxbury Supplementary Rules and Regulations 1.10(1)(b) allowing the proposed SAS to be constructed 122.7' from the homeowners potable well vs. the required 150'. ( Title 5 requires 100' vs Town of Duxbury 150')

COMMENTS:

1. This is an existing four bedroom dwelling with no proposed increase in flow
2. This property is located in a Zone II Wellhead Protection Area.
3. This system is not designed for a garbage grinder.
4. A copy of the passing water quality report shall be provided to the Board of Health.