

REQUEST FOR VARIANCE(S) FROM BOARD OF HEALTH
DECISION NEEDED BY JULY 7, 2022

STREET ADDRESS: 35 North Street

CURRENT BEDROOMS: 4 DSCP REQUESTED BEDROOMS: 4

PARCEL #: 036-058-003

CURRENT OWNER: Kerry Smith

MOVE: To **Grant/Deny** a variance to Duxbury Supplementary Rules and Regulations 1.10(1)(b) allowing the proposed SAS to be constructed 115' from the homeowners potable well vs. the required 150'.

COMMENTS:

1. This is an existing four bedroom dwelling with no proposed increase in flow
2. This property is located in a Zone II Wellhead Protection Area.
3. The existing septic system has failed.
4. This system is not designed for a garbage grinder.