

REQUEST FOR VARIANCE (S) FROM BOARD OF HEALTH
DECISION NEEDED BY December 9,2020

STREET ADDRESS: 534 Washington St
CURRENT BEDROOMS: 5 DSCP REQUESTED BEDROOMS: 5
PARCEL NUMBER: 118-009-207
CURRENT OWNER: John and Heather Cully

MOVE: To Grant/Deny a Title 5 local upgrade approval to 310 CMR 15.22(1)(7) to allow the system components to increase maximum allowable depth between 36" to 72" (36"-48" proposed) vs. the required 36". Adequate venting, access, and H-20 Loading will be provided.

COMMENTS/FINDINGS:

1. This is an existing five (5) bedroom dwelling with no proposed increase in flow.
2. This property does not fall within a Zone II
3. This system is not designed for a garbage grinder.