

Lab ID. # 108175R

To: Duxbury Board of Health Attn: Ms. Tracy Mayo 878 Tremont Street Duxbury, MA 02332

Received Date/Time:	7/7/23, 4:30 PM
Analyzed Date/Time:	7/7/23, 4:35 PM
Reported Date:	7/8/23
Collected By:	Client
Collection Date:	7/7/23

ANALYTICAL RESULTS

Sample#	Sampling Location	Sampling Time	Enterococci (MPN/100mL)
3	West End	2:05 PM	<10
Maximum Contaminant Level			104
Method of Reference			Enterolert Method

Laboratory QC Results

QC	Unit	Enterococci
Duplicate (D1)	100mL	<10
Duplicate (D2)	100mL	<10
Dilution Blank	100mL	< 1
Negative Control	100mL	Negative
Positive Control	100mL	Positive

Approved By: _____

Lab. Director

Date


7/10/23

